

No#	Pump Station Names	Area Supplied	Capacity of Station (litres)	Number of Person supplied by pump station	Per Person Consumption per day (litres)	Total consumption per day (Litres)	Maximum supply per station (Days)	Back up Generator availability (Yes /No)	Generator Fuel Capacity (Litres)	Run Time (hrs)
1	4th&5th Hall	4th & 5th Hall	38,000	124	100	12400	3.1	No		
2	6th&7th Hall	6th & 7th Hall	57,000	246	100	24600	2.3	No		
3	8th Hall	8th Hall	66,500	141	100	14100	4.7	Yes	15	26.9
4	2nd Hall	2nd Hall	18,500	46	100	4600	4.0	Yes	15	21.6
5	1st Hall	1st Hall	38,000	43	100	4300	8.8	No		
6	9th Hall	9th Hall	9,500	36	100	3600	2.6	No		
7	11th Hall	11th Hall	28,500	192	100	19200	1.5	No		
8	Statham	B201, B202, B203, B204, B205, B206 & B207	19,000	263	100	26300	0.7	Yes	300	12.6
9	Vaturara	MQ50A,B&C, 51A&B, 52A&B, 53A&B, 54A&B, 55A&B,	28,500	78	100	7800	3.7	Yes	15	25.9
10	MQ26	MQ25, 26, 27, 28, 29, 30, MQ31, 32 & 5 Boy House	19,000	51	100	5100	3.7	Yes	15	25.9
11	Catalina	MQ9, 10, 11, 12, SQ22A&B and 3 Boy House and Catalina Flats 1 - 6 Flat	40,000	90	100	9000	4.4	Yes	15	26.9
12	VCP's	VCP's residence	14,000	6	100	600	23.3	Yes	60	29.6
13	Namaste line	MQ39, 40, 41, 42, 43, 44, 45, 46 and 4 Boy House	19,000	52	100	5200	3.7	Yes	15	26.9
14	Waqavuka	Waqavuka Flats, MQ47 & MQ48 including Nursery	19,000	24	100	2400	7.9	No		
15	Security	Wespac bank,medical center,careers center,ITS Labs8,9,10,11,Halls office,mailroom and USPSA office	9,500	143	50	7150	1.3	Yes	15	26.9
16	Research	P&Q office,Research office,HR office ,Admin building and Conficious building	19,000	130	50	6500	2.9	No		
17	DMC	DMC office,Records office,Risk office,Secretariat office,MQ5,6,7 and 3Boy house	28,500	68	50	3400	8.4	Yes	30	25.9
18	MSP	MSP buliding,IAS Building ,school of Geography,lodges,security boot and PACE offices	19,000	180	50	9000	2.1	Yes	600	18.8
19	Engineering	Engineering blocks,Land Management building,CRC Gym and commerical office	19,000	334	50	16700	1.1	No		
20	Book Center	Book Center building, hot bread, supermarket and Media Annex	19,000	72	50	3600	5.3	No		
21	FSTE	FSTE buildings	28,500	678	50	33900	0.8	Yes	600	13.8
22	FBE	FBE buildings	19,000	1113	50	55650	0.3	Yes	600	16.6
23	Library	Library and FALE buildings	19,000	1062	50	53100	0.4	Yes	600	13.8
24	ICTCentre	Buildings A, B and C reserve tank only	14,000	693	50	34650	0.4	Yes	1100	47.4
25	SQ22	SQ22	9,500	7	100	700	13.6	No		
			618,500	5,872		363,550	4.4			